

**Assisted Living Facilities**  
**Life Safety Code Checklist For Large Type A Facilities – 40 TAC §92.61**

<b>Facility Name</b>		<b>Facility ID No.</b>		<b>Inspection Exit Date</b>	
<b>Street Address</b>	<b>City</b>	<b>State</b>	<b>ZIP Code</b>	<b>Area Code and Telephone No.</b>	

The items on the following checklist represent 40 Texas Administrative Code (TAC), Chapter 92, Licensing Standards for Assisted Living Facilities. Violations of licensure standards are identified on the appropriate checklist by the requirements checked Not Met. When violations are cited, a copy of the appropriate checklist is left with the facility at the exit conference. If additional violations are cited after the initial exit conference, an additional exit conference will be conducted regarding the newly identified violations, with specific reference to the standard violated. Other violations in areas not checked still may be pending from previous inspections and are not reflected on this current report.

**Note:** This checklist contains a brief description of the requirements. Refer to the licensure standards for a complete description of the requirements.

40 TAC Chapter 92	Assisted Living Facilities Life Safety Code Checklist for Large Type A Facilities – 40 TAC §92.61	Not Met
<b>Subchapter D. Facility Construction</b>		
<b>§92.61</b>	<b>Introduction and Application</b>	
<b>92.61(a)(3)</b>	New construction is any construction work that began on or after Jan. 6, 2014. Converting an unlicensed building or unlicensed portion of a building to an assisted living facility must meet the new construction requirements for the proposed new use referenced in the Life Safety Code.	
<b>92.61(a)(4)</b>	An existing facility is one that operated with a license as an assisted living facility before Jan. 6, 2014, and has not subsequently become unlicensed.	
<b>92.61(b)(4)</b> <b>92.61(b)(4)(A)</b>	Buildings and structures must comply with the 2000 edition of the National Fire Protection Association 101 (NFPA 101). All new Type A large facilities must comply with Chapter 32.3.	
<b>92.61(b)(4)(B)</b>	All existing Type A large facilities must comply with Chapter 33.3.	
<b>92.61(b)(4)(F)</b>	Buildings that contain living units with independent cooking and bathroom facilities must comply with Chapters 30, 31, 32 and 33.	
<b>NFPA 101</b>	All large Type A assisted living facilities must comply with the requirements of NFPA 101, the Life Safety Code, 2000 edition.	<input type="checkbox"/>
<b>32/33.3.2.1</b>	All means of egress shall be in accordance with Chapter 7.	<input type="checkbox"/>
<b>32/33.3.2.2.2(3)</b>	Doors comply with 7.2.1. No door in any means of egress shall be locked against egress when the building is occupied. Delayed egress locks complying with 7.2.1.6.1 are permitted.	<input type="checkbox"/>
<b>32/33.3.2.3.3</b>	The width of corridors shall be sufficient for the occupant load served but not less than 44 inches.	<input type="checkbox"/>
<b>32/33.3.2.5.1</b>	Exits shall be arranged such that, from any corridor room door, exits will be accessible in at least two different directions.	<input type="checkbox"/>
<b>32/33.3.2.6.1</b>	Travel distance within a room, suite or living area to a common door shall not exceed 125/75 feet.	<input type="checkbox"/>
<b>32/33.3.2.8</b>	Means of egress shall be illuminated in accordance with Section 7.8.	<input type="checkbox"/>
<b>32/33.3.2.9</b>	Emergency lighting in accordance with Section 7.9 shall be provided in all buildings with more than 25 rooms.	<input type="checkbox"/>
<b>32/33.3.3.1.1</b>	Every stairway, elevator shaft and other vertical opening shall be enclosed or protected in accordance with Section 8.2.5.	<input type="checkbox"/>
<b>32/33.3.3.6.2</b>	Sleeping rooms shall be separated from corridors and other common spaces by walls with a fire-resistance rating of not less than a half hour.	<input type="checkbox"/>
<b>32/33.3.3.6.4</b>	Doors in fire barriers shall have a fire protection rating of not less than 20 minutes.	<input type="checkbox"/>
<b>32/33.3.3.6.5</b>	Walls and doors required by 32/33.3.3.6 shall be constructed to resist the passage of smoke.	<input type="checkbox"/>
<b>32/33.3.3.7</b>	Every sleeping room floor shall be divided into at least two smoke compartments of approximately the same size unless the building is protected throughout with an approved automatic sprinkler system.	<input type="checkbox"/>
<b>Other Chapter 32/33.3</b>		

Signature of Inspection Team Member

Date